



Other System Charges (OSC) Trip Report
2023/2024



Date	Unit	MW Lost	Pre-incident [Hz]	Frequency Nadir [Hz]	Trip Type
04/10/2023 23:35	Synergen Power Ltd unit DB1	143.81		49.89	Fast Wind-down Trip
21/10/2023 08:24	Huntstown Power Co Ltd unit HNC	216.55		49.79	Direct Trip
21/10/2023 14:57	Huntstown Power Co Ltd unit HNC	147.19		49.86	Direct Trip
21/10/2023 21:30	Synergen Power Ltd unit DB1	425.16		49.8	Fast Wind-down Trip
23/11/2023 15:57	ESB Power Generation unit MP3	131.94		49.88	Direct Trip
11/01/2024 19:51	ESB Power Generation unit MP3	128.53		49.87	Slow Wind-down trip
16/01/2024 10:57	ESB Power Generation unit AD2	102.15		49.89	Fast Wind-down Trip
27/02/2024 03:05	ESB Power Generation unit MP2	116.4		49.86	Fast Wind-down Trip
27/02/2024 09:09	ESB Power Generation unit MP3	108.63		49.87	Direct Trip
07/03/2024 08:30	ESB Power Generation unit MP3	118.68		49.87	Direct Trip
28/03/2024 17:36	EP Ballylumford Limited	118.57		49.84	Direct Trip
11/04/2024 07:06	SSE Generation Ireland Ltd unit GI4	476.36		49.73	Direct Trip
31/05/2024 10:20	Huntstown Power Co Ltd unit HNC	115.25		49.88	Direct Trip