

**Other System Charges (OSC) Trip Report
2020/2021**

Date	Unit	MW Lost	Pre-incident [Hz]	Frequency Nadir [Hz]	Trip Type
02/10/2020 18:29	ESB Power Generation unit MP1	100.38		49.82	Slow Wind-down trip
27/10/2020 19:54	Ballylumford CCGT unit 32	221.925		49.858	Direct Trip
30/10/2020 09:23	Tynagh Energy Limited unit TYC	310.35		49.81	Slow Wind-down trip
31/10/2020 00:47	SSE Generation Ireland Ltd unit GI4	100.31		49.94	Fast Wind-down Trip
12/11/2020 07:31	Synergen Power Ltd unit DB1	325.07		49.75	Fast Wind-down Trip
30/11/2020 10:38	Huntstown Power Co Ltd unit HNC	161.89		49.88	Direct Trip
02/12/2020 08:14	Bord Gais Energy Ltd unit WG1	441.8		49.58	Direct Trip
03/12/2020 18:45	SSE Generation Ireland Ltd unit TB4	185.63		49.89	Fast Wind-down Trip
06/03/2021 20:20	Ballylumford CCGT unit 31	121.096		49.79	Direct Trip
19/03/2021 17:10	SSE Generation Ireland Ltd unit TB4	112.94		49.87	Direct Trip
04/04/2021 09:17	SSE Generation Ireland Ltd unit TB4	137.02		49.86	Direct Trip
06/04/2021 01:58	Tynagh Energy Limited unit TYC	278.19		49.75	Direct Trip
06/04/2021 20:07	Tynagh Energy Limited unit TYC	109.22		49.93	Fast Wind-down Trip
22/04/2021 20:33	Ballylumford CCGT unit 31	198.73		49.798	Direct Trip
04/05/2021 20:03	Coolkeeragh ESB Limited C30	404.575		49.701	Direct Trip
17/05/2021 08:20	SSE Generation Ireland Ltd unit TB3	180.1		49.79	Direct Trip
02/06/2021 13:34	ESB Power Generation unit AD2	115.48		49.9	Fast Wind-down Trip
02/06/2021 14:15	ESB Power Generation unit AD2	198.11		49.86	Fast Wind-down Trip
02/06/2021 15:19	ESB Power Generation unit AD2	139.3		49.84	Fast Wind-down Trip
29/06/2021 19:01	SSE Generation Ireland Ltd unit TB3	123.93		49.88	Fast Wind-down Trip
03/07/2021 16:03	Tynagh Energy Limited unit TYC	359.05		49.67	Direct Trip
10/07/2021 12:50	Huntstown Power Co Ltd unit HNC	193.33		49.74	Direct Trip
23/07/2021 07:04	ESB Power Generation unit MP1	272.82		49.78	Fast Wind-down Trip
27/07/2021 15:28	SSE Generation Ireland Ltd unit TB3	119.53		49.82	Fast Wind-down Trip